

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/23/2025	Date Reported: 10/02/2025
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: <b>1280285 RE</b>	PWS Name: <b>Ramsey Estates Water</b>
County: Kootenai	

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www accuratetesting.com  
E-mail: info@accuratetesting.com

**Order Number: 2025090807**

**INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER**

	<b>Copper</b>	<b>Lead</b>		
Action Level (AL):	1.3 mg/L	0.015 mg/l		
Test Method:	EPA 200.5	EPA 200.5		
Analyst:	WM	WM		
<b>Lab Sample #</b>	<b>Date Collected</b>	<b>Sampling Location</b>	<b>Copper mg/L</b>	<b>Lead mg/L</b>
288150	09/23/2025	1142 Laramie	0.0530	ND
288151	09/23/2025	1355 Laramie	0.0620	ND
288152	09/23/2025	1481 Chaparral	0.0525	ND
288153	09/23/2025	22907 El Dorado	0.0288	ND
288154	09/23/2025	1576 Chaparral	0.0785	ND

Ramsey Estates Water  
22904 N Eldorado Dr  
Rathdrum, ID 83858



10/02/25

Laboratory Supervisor, Digitally signed by: *Walter*